

CERTIFICATE OF CONSTANCY OF PERFORMANCE

20-CPR-312-(C-18/2018)

In compliance with Government decree no. 275/2013. (issued on 16th July) this certificate applies to the construction product

**Weldable, ribbed, hot rolled reinforcing steel in bars made by
Abinsk Electric Steel Works LTD. in steel quality B500B (DIN 488-1:2009 and
MSZ/T 339:2012.03) with $R_{eH} = 500$ MPa declared yield strength
calculated from nominal cross-section**

with product performance and intended use shown in the annex as page 2/2 of this certificate and produced by

Abinsk Electric Steel Works LTD.

353320 Abinsk, Krasnodar region, Promyshlennaya str.4.,Russia

and produced in the manufacturing plant:

Abinsk Electric Steel Works LTD.

353320 Abinsk, Krasnodar region, Promyshlennaya str.4.,Russia


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in **National Technical Assessment no. A-24/2018 dated at 10.12.2018** under system (1+) are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 17.12.2018 and will remain valid as long as the test methods and/or factory production control requirements included in the National Technical Assessment, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

This certificate consists of 2 pages!

Dated at Szentendre, 17th December 2018



Molnár Ágnes
Head of Certification Office
Certification Office
of ÉMI Non-profit Ltd.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

20-CPR-312-(C-18/2018)

ANNEX

Nominal diameters:

Ø8 – Ø22 mm

Intended use of the product:

The steel bars may be used as reinforcement of concrete structures according to EN 10080:2005, in steel quality B500B (DIN 488-1:2009 and MSZ/T 339:2012.03).

The reinforcing steel bars can be taken into account with the parameters of reinforcing steels made from B60.50 (MSZ 339:1987) by performing diagnostic works on building designed in accordance with withdrawn standards series no. MSZ 15022:1986 and no. MSZ 15022:1986/1M:1992.

The reinforcing steel bars can be taken into account as product in ductility class B with $R_{eH} = 500$ MPa declared yield strength calculated from nominal cross-section at design works and strength calculations, according to Annex C of standard no. EN 1992-1-1:2010 (EUROCODE 2).

Essential characteristics	Performance
Yield or proof strength (R_{eH} or $R_{p0,2}$) ¹⁾	≥ 500 MPa (characteristic) ≥ 485 MPa (individual)
Tensile strength (R_m)	≥ 580 MPa (characteristic) ≥ 563 MPa (individual)
Stress ratio, R_m / R_{eH}	≥ 1.08 (characteristic) ≥ 1.06 (individual)
Yield ratio, $R_{e,act} / R_{e,nom}$	≤ 1.30 (individual)
Extension (A_{gt})	≥ 5.0 % (characteristic) ≥ 4.5 % (individual)
Elongation, A_5	≥ 18,0 % (average)
Bendability	180 degrees: $d \leq 16$ mm: 3d mandrel $d > 16$ mm: 6d mandrel
Tolerances from nominal cross-section	$d = 8$ mm: ± 6,0 $d > 8$ mm: ± 4,5
Bonding strength (f_R)	8 mm ≤ d ≤ 12 mm: 0,040 $d > 12$ mm: 0,056
Weldability (C_{eq} or CEV):	$C_{eq} \leq 0.52$
Weld metal bend test for 150°, without cracks in the transition zone	$d \geq 16$ mm: 3d mandrel
Impact strength on 0 °C-on, KV (J) $d \geq 16$ mm	average ≥ 28 individual value ≥ 21 (75%)
Durability (product analysis)	$C \leq 0.24$; $S \leq 0.055$; $P \leq 0.055$; $N_2 \leq 0.014$; $Cu \leq 0.85$
¹⁾ Upper yield strength (R_{eH}), when real yield phenomena occurs, otherwise proof strength ($R_{p0,2}$)	

Dated at Szentendre, 17th December 2018

